

2021 Water Quality Report for Presque Isle Harbor Water Company

P O Box W, 255 Belmont St, Waymart, Pennsylvania, 18472 Tel:(570)488-5222 Fax:1-866-355-9483

This report covers the drinking water quality for **Presque Isle Harbor Water Company** for calendar year **2021**. This information is a snapshot of the quality of the water that we provided to you in 2021. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and MI State standards. Your water comes from two groundwater wells located on **Kauffman Rd, Presque Isle, MI**. The State performed an assessment of our source water in 2021. Copies of reports are available from Presque Isle Harbor Water Company. Our wells were determined to have moderately low susceptibility to contamination by the MI EGLE. This report contains very important information about your drinking water. Translate it, or speak with someone who understands it. (*Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.*)

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
- Contaminants that may be present in source water include:
 - * **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - * **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharge, oil and gas production, mining or farming.
 - * **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - * **Radio Active contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
 - * **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Presque Isle Harbor Water Company is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line, it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the USEPA's Safe Drinking Water Hotline or at (<http://water.epa.gov/drink/info/lead/index.cfm>).

Water Quality Data

The table below lists all the drinking water contaminants that have been detected during the 2021 calendar year or before. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2021. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- N/A: not applicable ND: not detectable at testing limit ppb: parts per billion or micrograms per liter ppm: parts per million or milligrams per liter pCi/l: picocuries per liter (a measure of radioactivity). RAA: Running Annual Average
- Action Level (AL): Concentration of a contaminant which, if exceeded, triggers treatment or other requirements a water system must follow.

Samples Collected at the Well House:

Regulated Inorganic Contaminants	MCL	MCLG	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Fluoride (ppm)	4.0	0.1	1.2	09/09/2021	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppm)	2	0.01	0.03	09/28/2020	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits

Unregulated Chemical Contaminants ¹	Our Water	Sample Date	Violation Yes / No	Typical Source of Contaminants
Sodium (ppm)	39	09/09/2021	No	Erosion of natural deposits, runoff.
Sulfate (ppm)	70	09/09/2021	No	Erosion of natural deposits, runoff.
Chloride (ppm)	32	09/10/2021	No	Erosion of natural deposits, runoff.
Iron (ppm)	0.71	09/09/2021	No	Erosion of natural deposits, runoff.
Hardness (ppm)	280	09/09/2021	No	Erosion of natural deposits, runoff

Samples Collected in the Distribution System:

¹90 percent of the samples collected were at or below the level reported for our water.

Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water ^[1]	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15 ppb	0 ppb	1.0 ppb 90 th Percentile	0 ppb To 0.001ppb	9/28/2021	None	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3 ppm	1.3 ppm	55 ppb 90 th Percentile	0.05ppm To 0.48ppm	9/28/2021	None	Corrosion of household plumbing systems; Erosion of natural deposits

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Total Coliform (total number or % of positive samples/month)	TT	N/A	N/A	N/A	2021	No	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note ^[2]	0	N/A	N/A	2021	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	N/A	N/A	2021	No	Human and animal fecal waste

² *E. coli* MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or (2) the supply fails to take all required repeat samples following *E. coli*-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for *E. coli*.

Monitoring and Reporting Requirements: The State and USEPA requires us to test our water on a regular basis to ensure its safety. This is Presque Isle Harbor Water Company monitoring and reporting requirements for 2021. We made a mistake with the August water samples last year and the Violation Notice is attached. We will update this report annually and will keep you informed of any problems that may occur through the year as they happen. For more information about your water, or the contents of this report, contact Presque Isle Harbor Water Company at (570) 488-5222. For more information about safe drinking water, visit the USEPA at www.epa.gov/safewater/.

You may also contact the water company via email at chad@pihwr.com. Thank you and have a great day.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER***Monitoring Requirements Not Met for Presque Isle Harbor Water Company***

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During August 1 to August 31, 2021, we did not monitor or test for total coliform bacteria and, therefore, cannot be sure of the quality of your drinking water during that time.

What should I do?

There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. Even though this is not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

The table below lists the contaminant we did not properly test for, how often we are supposed to sample for this contaminant, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date we collected follow-up samples.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	Date additional samples were taken
Total Coliform Bacteria	1 sample per month	0	August 1, 2021 to August 31, 2021	September 8, 2021

What happened? What is being done?

We inadvertently missed taking a sample within this required sampling period. We are making every effort to ensure this does not happen again. We returned to compliance on September 8, 2021.

For more information, please contact Presque Isle Harbor Water Company (989)595-2751

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Presque Isle Harbor Water Company.

CERTIFICATION:

WSSN: 05575

I certify that this water supply has fully complied with the public notification regulations in the Michigan Safe Drinking Water Act, 1976 PA 399, as amended, and the administrative rules.

Signature: Chad Hall Title: Operator Date Distributed: 6-30-2022

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Presque Isle Harbor Water Company is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.